

Annual Drinking Water Quality Report for 2020
Development Authority of the North Country Watertown to Fort Drum Waterline
P1482 St. Lawrence Avenue & 4th Street
(Public Water Supply ID#2230013)

INTRODUCTION

To comply with State regulations, the Development Authority of the North Country will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards. If you have any questions about this report or concerning your drinking water, please contact **The Development Authority of the North Country, 661-3210**. We want you to be informed about your drinking water. We would be happy to discuss any drinking water issues with you in person. If you want to learn more, please contact our office.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves Fort Drum and several water districts in the Town's of Pamela, LeRay and Champion. Our water source is the Black River. Attached is a copy of the Annual Water Quality Report as supplied by the City of Watertown. The water is pumped from the City of Watertown's clearwell using one of three 75 horsepower centrifugal pumps through a 20-inch ductile iron pipeline to Fort Drum. These pumps are located in Booster Pump Station #1, located on Route 3 near the City's Water Filtration Plant. The water is pumped to a 750,000 gallon ground storage tank located on Fort Drum. Also attached is a copy of the Source Water Assessment Program report completed by the Department of Health for the City of Watertown.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for contaminants. These contaminants include: Total Coliform, Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5). Of the compounds we analyzed for, Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5) were detected in your drinking water. It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the New York State Health Department at 785-2277.

Microbiological

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Health Effects
Total Coliform	No	2020	0	N/A	N/A	MCL=2 or more positive samples in 1 month ¹	Naturally Present in the environment.

¹ A violation occurs at systems collecting 40 or more samples per month when more than 5% of the total coliform samples are positive. A violation occurs at systems collecting less than 40 samples per month when two or more samples are total coliform positive

Disinfection Byproducts

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected Avg (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Health Effects
Total Trihalomethanes (TTHMs – chloroform, bromodichloromethane, dibromochloromethane, and bromoform)	NO	2020	36.1 ² (14- 48.2)	ug/l	N/A	MCL=80	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter.
Haloacetic Acids (HAA5)	NO	2020	41.2 ² (13.5 -48.8)	ug/l	N/A	MCL=60	By-product of drinking water chlorination

² This level represents the highest locational running average calculated from the data collected.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2020, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

INFORMATION ON FLUORIDE ADDITION

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. Fluoride is added to your water by the City of Watertown and before it is delivered to us. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at an optimal range from 0.8 to 1.3 mg/l (parts per million). To ensure that the fluoride supplement in your water provides optimal dental protection, the State Department of Health requires that the City of Watertown monitor fluoride levels on a daily basis. During 2020 monitoring showed fluoride levels in your water were in the optimal range 100 % of the time. None of the monitoring results showed fluoride at levels that approach the 2.2 mg/l MCL for fluoride.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your organization/family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office, 661-3210, if you have questions.

City of Watertown 2020 Annual Water Quality Report

Spanish (Español)

Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúscalo o hable con alguien que lo entienda bien.

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies. Last year, we conducted tests for over 80 contaminants. We only detected 15 of those contaminants, and found only 2 at a level higher than the EPA allows. As we informed you at the time, our water temporarily exceeded drinking water standards. (For more information see the section labeled Violations at the end of the report.)

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source is the Black River, a surface water source, which originates in the Adirondack Mountains and runs through the center of the City and westerly to Black River Bay. During 2017 our system did not experience any restriction of our water source. Flows in the Black River are regulated by the Hudson-Black River Regulating District and are controlled by a series of hydro-electric power dams stretching from its headwaters in the Adirondacks to its mouth in Lake Ontario. If the City of Watertown's 15 million gallon per day Water Treatment Plant were running at full capacity, it would need only 2.3% of the minimum flow of the Black River. The water is treated within modern facilities prior to distribution. The water filtration building and main pumping station were reconstructed in 1987-1991. Liquid Alum and a nonionic polymer are added to the water to coagulate and settle out dirt and organic matter through a dosing station upstream of the water plant. The settled water is then pumped to the process complex at 1707 Huntington Street. Polyaluminum chloride and nonionic or cationic polymer are added prior to filtering. Carbon may be added to combat taste and odor. The filtered water is disinfected with chlorine to kill bacteria, viruses, and other microorganisms. The water is then treated with sodium silicate for corrosion control and with fluoride to help fight tooth decay. The finished potable water is pumped to the City's distribution system and through the Development Authority of the North Country's line to the Towns of Champion, LeRay, and Pamela.

Source water assessment and its availability

The NYSDOH has evaluated this PWS's (public water supply's) susceptibility to contamination under the Source Water Assessment Program (SWAP), and their findings are summarized in the paragraph below. It is important to stress that these assessments were created using available information and only estimate the potential for source water contamination. Elevated susceptibility ratings do not mean that source water contamination has or will occur for this PWS. This PWS provides treatment and regular monitoring to ensure the water delivered to consumers meets all applicable standards.

Overall, this water supply is most susceptible to microbial contaminants, primarily from pasture and permitted discharges within the watershed. Sediment and turbidity associated with mining operations is also a concern, and transportation routes also have a potential to contribute various contaminants. A copy of the assessment can be obtained by contacting the supplier of water.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

If you have any questions about this report or concerning your drinking water, please contact Vicky L. Murphy, Superintendent of Water, at (315) 785-7757. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled City Council meetings. Significant items of agenda are normally printed in the Watertown Daily Times a few days prior to the meeting. The meetings are on the first and third Mondays of the month at 7:00 pm in the City Council chambers located on the third floor of City Hall, 245 Washington Street, Watertown, New York. Notices of Public Hearings are always printed in the newspaper prior to the meeting under "Legal Notices" in the classified section.

Description of Water Treatment Process

Your water is treated in a "treatment train" (a series of processes applied in a sequence) that includes coagulation, flocculation, sedimentation, filtration, and disinfection. Coagulation removes dirt and other particles suspended in the source water by adding chemicals (coagulants) to form tiny sticky particles called "floc," which attract the dirt particles. Flocculation (the formation of larger flocs from smaller flocs) is achieved using gentle, constant mixing. The heavy particles settle naturally out of the water in a sedimentation basin. The clear water then moves to the filtration process where the water passes through sand, gravel, charcoal or other filters that remove even smaller particles. A small amount of chlorine or other disinfection method is used to kill bacteria and other microorganisms (viruses, cysts, etc.) that may be in the water before water is stored and distributed to homes and businesses in the community.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are

many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Where do TTHM's and HAA5's come from?

The City has had continual difficulties meeting the requirements for the Stage II DBP levels for THM and HAA5. Violations occur when the running average for an individual location exceed the MCL. The running average is calculated with the 4 most recent quarter results for an individual site. A violation that occurs at a single site that is not isolated from the rest of the system requires a city wide notification. During 2020 our system had MCL exceeds during the second quarter for THM and the third quarter for THM and HAA5's resulting in City wide mailings.

Trihalomethanes and Haloacetic acids are a groups of chemicals that are formed in drinking water during treatment by chlorine, which reacts with certain acids that are in naturally-occurring organic material (e.g., decomposing vegetation such as tree leaves, algae or other aquatic plants) in surface water sources such as rivers and lakes. The amount of Trihalomethanes and Haloacetic acids in drinking water can change from day to day, depending on the temperature, the amount of organic material in the water, the amount of chlorine added, and a variety of other factors. Drinking water is disinfected by public water suppliers to kill bacteria and viruses that could cause serious illnesses. Chlorine is the most commonly used disinfectant in New York State. For this reason, disinfection of drinking water by chlorination is beneficial to public health.

IMPORTANT INFORMATION ABOUT THM'S

Some studies suggest that people who drink chlorinated water (which contains trihalomethanes) or water containing elevated levels of trihalomethanes for long periods of time may have an increased risk for certain health effects. For example, some studies of people who drank chlorinated drinking water for 20 to 30 years show that long term exposure to disinfection by-products (including trihalomethanes) is associated with an increased risk for certain types of cancer. A few studies of women who drank water containing trihalomethanes during pregnancy show an association between exposure to elevated levels of trihalomethanes and small increased risks for low birth weights, miscarriages and birth defects. However, in each of the studies, how long and how frequently people actually drank the water, as well as how much trihalomethanes the water contained is not known for certain. Therefore, we do not know for sure if the observed increases in risk for cancer and other health effects are due to trihalomethanes or some other factor.

The individual trihalomethanes chloroform, bromodichloromethane and dibromochloromethane cause cancer in laboratory animals exposed to high levels over their lifetimes. Chloroform, bromodichloromethane and dibromochloromethane are also known to cause effects in laboratory animals after high levels of exposure, primarily on the liver, kidney, nervous system and on their ability to bear healthy offspring. Chemicals that cause adverse health effects in laboratory animals after high levels of exposure may pose a risk for adverse health effects in humans exposed to lower levels over long periods of time.

IMPORTANT INFORMATION ABOUT HAA5's

Some studies of people who drank chlorinated drinking water for 20 to 30 years show that long term exposure to disinfection by-products (possibly including haloacetic acids) is associated with an increased risk for certain types of cancer. However, how long and how frequently people actually drank the water as well as how much haloacetic acids the water contained is not known for certain. Therefore, we do not know for sure if the observed increased risk for cancer is due to haloacetic acids, other disinfection by-products, or some other factor.

The individual haloacetic acids dichloroacetic acid and trichloroacetic acid cause cancer in laboratory animals exposed to high levels over their lifetimes. Dichloroacetic acid and trichloroacetic acid are also known to cause other effects in laboratory animals after high levels of exposure, primarily on the liver, kidney and nervous system and on their ability to bear healthy offspring. Chemicals that cause effects in animals after high levels of exposure may pose a risk to humans exposed to similar or lower levels over long periods of time.

Results of Cryptosporidium monitoring

Cryptosporidium is a microbial pathogen found in surface water throughout the U.S. Although filtration removes cryptosporidium, the most commonly-used filtration methods cannot guarantee 100 percent removal. Our monitoring indicates the presence of these organisms in our source water and/or finished water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of cryptosporidium may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people are at greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. Cryptosporidium must be ingested to cause disease, and it may be spread through means other than drinking water.

Results of voluntary monitoring

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Watertown is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Haloacetic Acids (HAA5) (ppb)	NA	60	62.6	24.3	85.6	2020	Yes	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	84.8	25.3	115.9	2020	Yes	By-product of drinking water disinfection
Total Organic Carbon (% Removal)	NA	TT	NA	NA	NA	2020	No	Naturally present in the environment
Inorganic Contaminants								
Asbestos (MFL)	7	7	1	NA	NA	2014	No	Decay of asbestos cement water mains; Erosion of natural deposits
Barium (ppm)	2	2	.017	NA	NA	2019	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	100	100	NA	NA	NA	2020	No	
Fluoride (ppm)	4	4	.97	.6	.97	2020	No	Erosion of natural deposits; Water additive which promotes strong teeth;
Nitrate [measured as Nitrogen] (ppm)	10	10	NA	NA	NA	2020	No	
Microbiological Contaminants								
Turbidity (NTU)	NA	0.3	100	NA	NA	2020	No	Soil runoff
100% of the samples were below the TT value of .3. A value less than 95% constitutes a TT violation. The highest single measurement was .28. Any measurement in excess of 1 is a violation unless otherwise approved by the state.								
Radioactive Contaminants								
Radium (combined 226/228) (pCi/L)	0	5	.88	NA	NA	2020	No	Erosion of natural deposits
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	.41	2019	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	12	2019	3	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Violations and Exceedances	
Haloacetic Acids (HAA5)	
Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer. The violation occurred during the 3rd quarter of 2020 and lasted until the 4th quarter. The City installed automatic hydrant flusher at sites to flush water daily to remove DBP contaminates.	
TTHMs [Total Trihalomethanes]	
Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer. The City was in violation of the Stage II Disinfection By Product rule for two consecutive quarters, 2nd and 3rd quarters of 2020. The City installed automatic hydrant flusher at sites to flush water daily to remove DBP contaminates.	

Additional Monitoring

As part of an on-going evaluation program the EPA has required us to monitor some additional contaminants/chemicals. Information collected through the monitoring of these contaminants/chemicals will help to ensure that future decisions on drinking water standards are based on sound science.

Name	Reported Level	Range	
		Low	High
HAA6Br (ug/L)	2.95	2.36	3.9
HAA9 (ug/L)	44.99	22.9	75
manganese (ug/L)	21.7	13.7	34.1

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)

Unit Descriptions	
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
MFL	MFL: million fibers per liter, used to measure asbestos concentration
NTU	NTU: Nephelometric Turbidity Units. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Aaron Harvill
Address: 1707 Huntington St
Watertown, NY 13601
Phone: 315-785-7845